

TECHNICAL SPECIFICATION

Khorasan Electric Ind. Co



Cable 3 x 2.5 Fire Alarm

Cable Layer Construction		CU . XLPE . SC . LSHF		LV		
Standard Matching		Khorasan Electric				
R	Description			Unit	Specification	
1	Conductor	CU	Material	***	Annealed Copper	
			Conductor Type	***	Class 5 (RF)	
			Nominal Cross Section	L	mm ²	1 x 2.5
				N	mm ²	1 x 2.5
				PE	mm ²	1 x 2.5
			Number & Diameter of Wires	L	no * mm	50 x 0.24
				N	no * mm	50 x 0.24
PE	no * mm	50 x 0.24				
Shape	***	Round				
2	Insulation	XLPE	Material	***	Extruded XLPE	
			Thickness	L	mm	0.7
				N	mm	0.7
				PE	mm	0.7
Colour	L: Black , N:Blue ,PE:Yellow,Green					
4	Wrapping	SC	Material	***	Polyester Tape	
			Thickness	mm	0.036	
			Material	***	Aluminum	
			Thickness	mm	0.036	
5	Shield	SC	Material	***	Annealed Copper	
Number & diameter of wires	mm		24 x 6 x 0.12			
6	Outer Sheath	LSHF	Material	***	Extruded LSHF	
			Thickness	mm	1.1	
			Colour	***	Red	
7	Special Properties	Standard	Low Smoke	IEC 61034		
			Flame Retardant	IEC 60332-1-2		
			Halogen Acid Gas	IEC 60754-1,2		
8	Approx. overall diameter of cable			mm	9.9	
9	Approx. Weight of cable			Kg /k	145	
10	Packing			***	Drum	
11	Rated Voltage U0 / U(Um)			KV	300 / 500	
12	System Frequency			Hz	50	
13	Max conductor resistance At 20° C			Phase	Ω/ Km	7.98
				Null		
14	Short circuit withstand current / time5s			KA	0.2	
15	Cable Voltage test			KV	2	
16	Max.Short circuit withstand current temperature			°C	+ 250	
17	Operation temperature			°C	-30 to +90	

(افشار نژاد) KHORASAN ELECTRIC IND.CO 300/500V CU/XLPE/SC/LSHF 3x2.5 mm² RF FLEXIBLE MADE IN IRAN